



## ADDENDUM # 4

**To: File 1905-909-23-4929**  
**IFB for: Cassiano Burn Units Rehabilitation**

### Please note the following changes:

1. The bid due date and time are changed to August 21, 2019 at 2:00 pm.

### The following questions are asked:

**Question 1:** The existing windows appear to be: Single Hung instead of Double Hung as shown on the plans will single hung windows be acceptable?

**Answer 1:** All windows are in different conditions.

- a. Contractor is to verify the condition of all existing windows and determine whether the windows are to be repaired or replaced.
- b. All windows are to Match Existing.
  - i. Some windows will only need to have pane/ glazing replaced.
  - ii. Some windows will need to have the frames replaced.
  - iii. Some windows will need the entire unit replaced as necessary.

**Question 2:** The existing windows appear to be Non-thermal break aluminum, are Non-Thermal Break Aluminum windows acceptable?

**Answer 2:** The windows will not be thermally broken

**Question 3:** The existing windows are a mix of single pane glass and insulated glass is insulated standard Low-E glass acceptable?

**Answer 3:** Yes, insulated standard low-e glass acceptable.

**Question 4:** The existing windows are a mix of mill finish with paint over them and Bronze, what should the finish be Mill or Bronze?

**Answer 4:** Mill finish should be acceptable. The finish should match existing. Contractor is to verify finish.



818 S. FLORES ST. ⓘ SAN ANTONIO, TEXAS 78204 ⓘ [www.saha.org](http://www.saha.org)

---

**Question 5:** Window F as drawn on plans (twin single hung) does not meet egress codes, is changing Window F to a single hung to meet egress codes acceptable?

**Answer 5:** For 1818 Krocker, 942 Merida with Window "F" will need to meet egress requirements.  
a. This may result in replacement of the entire window to meet egress requirements.  
b. This can be resolved with replacing the entire window with a single hung windows as specified.

By: *Charles R Bode*  
Charles Bode Asst. Director of Procurement

Date: August 13, 2019